



NOTES:

1. THRUST AND BEARING BLOCKING TO BE IN CONFORMANCE TO BSWSD: 26-01
2. FOR BOLTED FITTINGS, BLOCKING SHALL NOT OBSTRUCT BOLTS.
3. HYDRANT WEEP HOLES TO REMAIN UNOBSTRUCTED.

DETAIL NO.:
BSWSD:
26-04

**BIG SKY WSD 363
STANDARD DRAWING**

SCALE:
NONE

FIRE HYDRANT SETTING

DATE:
FEBRUARY 2010
LAST REVISION:
MARCH 2016
CROSS REFERENCE WITH:
MPW-6-NO. 02660-4