



NOTES:

1. THRUST AND BEARING BLOCKING TO BE IN CONFORMANCE TO BSWSD: 26-01 AND BSWSD: 26-03
2. FOR BOLTED FITTINGS, BLOCKING SHALL NOT OBSTRUCT BOLTS.
3. HYDRANT WEEP HOLES TO REMAIN UNOBSTRUCTED.

DETAIL NO.:

**BIG SKY WSD 363
STANDARD DRAWING**

SCALE:
NONE

FIRE HYDRANT SETTING

BSWSD:
26-04

DATE:	FEBRUARY 2010
LAST REVISION:	AUGUST 2002
CROSS REFERENCE WITH:	MPW-6-NO. 02660-4