



**NOTES:**

1. WATER SERVICE LINE INSTALLATION SHALL CONFORM TO THE REQUIREMENTS OF THE BIG SKY WATER AND SEWER DISTRICT (BSWSD).
2. ALL WATER SERVICE LINES SHALL BE A MINIMUM OF 1"  $\phi$  AND SHALL BE CLASS SDR-7, PE-4710 POLYETHYLENE PRESSURE PIPE MINIMUM 250 PSI PRESSURE RATING. PIPE SHALL BE PERFORMANCE PIPE A DIVISION OF CHEVRON PHILLIPS CHEMICAL COMPANY DRISCOPEX 5100 SERIES ULTRALINE HDPE PIPE AND TUBING OR A BSWSD APPROVED EQUAL.
3. SERVICE LINES SHALL BE BEDDED 6" UNDER AND OVER THE PIPE WITH 3/4" WASHED (NOT SCREENED) GRAVEL.
4. MINIMUM COVER FOR SERVICE LINES SHALL BE MEASURED FROM EXISTING GROUND LINE AND SHALL BE A MINIMUM OF 7' AND A MAXIMUM OF 8'.
5. ALL SERVICE LINES MUST BE INSULATED WITH 2" THICK BY 24" WIDE FOAM BOARD INSULATION FROM THE CORPORATION STOP AT THE MAIN TO THE CURB STOP AT THE PROPERTY LINE.
6. ALL SERVICE LINES SHALL BE INSTALLED WITH #12-THNN LOCATE WIRE.

DETAIL NO.:

BSWSD:  
26-06

**BIG SKY WSD 363  
STANDARD DRAWING**

SCALE:  
NONE

WATER SERVICE LINE

DATE:

FEBRUARY 2010

LAST REVISION:

MAY 11, 2010

CROSS REFERENCE WITH:

MPW-6-NO. 02660-6