



NOTES:

1. WATER SERVICE LINE INSTALLATION SHALL CONFORM TO THE REQUIREMENTS OF THE BIG SKY WATER AND SEWER DISTRICT (BSWSD).
2. ALL WATER SERVICE LINES SHALL BE A MINIMUM OF 1" Ø AND SHALL BE CLASS SDR-7, PE-4710 POLYETHYLENE PRESSURE PIPE MINIMUM 250 PSI PRESSURE RATING. PIPE SHALL BE PERFORMANCE PIPE A DIVISION OF CHEVRON PHILLIPS CHEMICAL COMPANY DRISCOPEX 5100 SERIES ULTRALINE HDPE PIPE AND TUBING OR A BSWSD APPROVED EQUAL.
3. SERVICE LINES SHALL BE BEDDED **6" UNDER** AND OVER THE PIPE WITH 3/4" WASHED (NOT SCREENED) GRAVEL THE FULL WIDTH OF THE TRENCH.
4. MINIMUM COVER FOR SERVICE LINES SHALL BE MEASURED FROM EXISTING GROUND LINE AND SHALL BE A MINIMUM OF 6.5' AND A MAXIMUM OF 8'.
5. ALL SERVICE LINES MUST BE INSULATED WITH 2" THICK BY 24" WIDE FOAM BOARD INSULATION FROM THE CORPORATION STOP AT THE MAIN TO THE CURB STOP AT THE PROPERTY LINE.
6. ALL SERVICE LINES SHALL BE INSTALLED WITH #12-THHN LOCATE WIRE.

DETAIL NO.: BSWSD: 26-06	BIG SKY WSD 363 STANDARD DRAWING	SCALE: NONE	WATER SERVICE LINE	DATE: FEBRUARY 2010
				LAST REVISION: MARCH 2016
				CROSS REFERENCE WITH: MPW-6-NO. 02660-6
				WATER SERVICE LINE