



NOTES:

1. PLACE BOLLARDS AROUND FIRE HYDRANTS LOCATED IN PARKING LOTS, ON ROADWAY SHOULDERS AND AT OTHER LOCATIONS WHERE HYDRANT IS SUCEPTIBLE TO VEHICULAR & EQUIPMENT DAMAGE.
2. BOLLARDS SHALL BE SET AT A MINIMUM OF 3 FEET BELOW FINISHED GRADE.
3. PAINT POSTS WITH SHERWIN-WILLIAMS METALATEX SEMI-GLOSS COATING, SAFETY RED (B42 R38 620-4069).
4. INSTALL A 3RD BOLLARD, ONLY IF REQUIRED BY BSWSD.

DETAIL NO.:

BSWSD:
26-08

**BIG SKY WSD 363
STANDARD DRAWING**

SCALE:
NONE

**BOLLARD PLACEMENT AT
FIRE HYDRANT**

DATE: FEBRUARY 2010
 LAST REVISION: MAY 11, 2010
 CROSS REFERENCE WITH: N/A