



NOTES:

1. PLACE BOLLARDS AROUND FIRE HYDRANTS LOCATED IN PARKING LOTS, ON ROADWAY SHOULDERS AND AT OTHER LOCATIONS WHERE HYDRANT IS SUCEPTIBLE TO VEHICULAR & EQUIPMENT DAMAGE.
2. BOLLARDS SHALL BE SET AT A MINIMUM OF 3 FEET BELOW FINISHED GRADE.
3. PAINT POSTS WITH SHERWIN-WILLIAMS METALATEX SEMI-GLOSS COATING, SAFETY RED (B42 R38 620-4069).
4. INSTALL A 3RD BOLLARD, ONLY IF REQUIRED BY BSWSD.

DETAIL NO.: BSWSD: 26-08	BIG SKY WSD 363 STANDARD DRAWING	SCALE: NONE	BOLLARD PLACEMENT AT FIRE HYDRANT	DATE: FEBRUARY 2010
				LAST REVISION: MARCH 2016
				CROSS REFERENCE WITH: N/A
				N/A