



- NOTE:**
1. POLYETHYLENE ENCASEMENT ON ALL DUCTILE IRON PIPE AND FITTINGS AS SPECIFIED.
 2. "MEGALUG" OR "UNI-FLANGE" JOINT RESTRAINTS MAY BE SUBSTITUTED FOR TIE RODS & THRUST BLOCKS.

DETAIL NO.:

BSWSD:
26-11

**BIG SKY WSD 363
STANDARD DRAWING**

SCALE:
NONE

**WATER MAIN CROSSING
BELOW EXISTING SEWER
MAIN**

DATE:

FEBRUARY 2010

LAST REVISION:

DECEMBER 2003

CROSS REFERENCE WITH:

COB: 02660-11