



NOTES:

1. GATE VALVE SHALL CONFORM TO AWWA C-500 OR C-509
2. VALVE BOXES SHALL BE PLUMB AND CENTERED DIRECTLY OVER THE VALVE NUT.
3. VALVE BOX TOP SHALL BE ADJUSTED TO MEET FINISHED GRADE.
4. VALVE EXTENSION SHALL BE INSTALLED WITH CENTERING RING AND WITHIN 1 FOOT OF FINISH GRADE. EXTENSIONS SHALL NOT BE ATTACHED TO VALVE.

DETAIL NO.:

BSWSD:
26-15

**BIG SKY WSD 363
STANDARD DRAWING**

SCALE:
NONE

**GATE VALVE & VALVE BOX
WITH THRUST BLOCK**

DATE:

FEBRUARY 2010

LAST REVISION:

APRIL 2005

CROSS REFERENCE WITH:

N/A