



NOTES:

1. GATE VALVE SHALL CONFORM TO AWWA C-500 OR C-509
2. VALVE BOXES SHALL BE PLUMB AND CENTERED DIRECTLY OVER THE VALVE NUT.
3. VALVE BOX TOP SHALL BE ADJUSTED TO MEET FINISHED GRADE.
4. VALVE EXTENSION SHALL BE INSTALLED WITH CENTERING RING AND WITHIN 1 FOOT OF FINISH GRADE. EXTENSIONS SHALL NOT BE ATTACHED TO VALVE.

DETAIL NO.: BSWSD: 26-15	BIG SKY WSD 363 STANDARD DRAWING	SCALE: NONE	GATE VALVE & VALVE BOX	DATE:
				FEBRUARY 2010
				LAST REVISION:
				MARCH 2016
				CROSS REFERENCE WITH:
				N/A