



**NOTES:**

1. WATER MAINS LOCATED 19' FROM THE NORTH OR WEST RIGHT-OF-WAY PROPERTY LINE FOR STREETS 35' IN WIDTH OR GREATER. WATER MAINS LOCATED 5.5' WEST OR NORTH OF STREET CENTERLINE FOR STREETS LESS THAN 35' IN WIDTH (BACK OF CURB-BACK OF CURB, IF APPLICABLE.)
2. WATER SERVICE STUB LOCATED AT CENTER OF LOT; SEE BSWSD STANDARD DRAWING 26-06 FOR DETAILS.
3. WATER MAIN VALVES LOCATED AT PROPERTY LINE.
4. SEWER MAINS LOCATED ON STREET CENTERLINE FOR STREETS 35' IN WIDTH OR GREATER. SEWER MAINS LOCATED 5.5' EAST OR SOUTH OF STREET CENTERLINE FOR STREETS LESS THAN 35' IN WIDTH.
5. SEWER SERVICE STUB LOCATED 15' UPSTREAM FROM DOWNSTREAM PROPERTY LINE.
6. WATER & SERVICE MAIN CROSSING; SEE BSWSD STANDARD DRAWING 26-02 FOR DETAILS.
7. HYDRANTS LOCATED 5' FROM VALVE OR ON PROPERTY LINES EXTENDED FOR MID-BLOCK LOCATIONS.

DETAIL NO.:

BSWSD:  
26-16

**BIG SKY WSD 363  
STANDARD DRAWING**

SCALE:  
NONE

**WATER & SEWER MAIN AND  
SERVICES LOCATION  
STANDARDS**

DATE:	FEBRUARY 2010
LAST REVISION:	DECEMBER 2003
CROSS REFERENCE WITH:	COB: 02660-16