



HORIZONTAL LAYER INSULATION			INVERTED U-INSULATION		
DEPTH OF BACKFILL OVER INSULATION	INSULATION THICKNESS	INSULATION WIDTH	DEPTH OF BACKFILL OVER INSULATION	INSULATION THICKNESS	2B+A ≥ WIDTH OF HORIZONTAL LAYER INSULATION
					2B + A
2'-0"	3.0"	5'-6"	2'-0"	3.0"	≥ 5'-6"
3'-0"	2.5"	5'-1"	3'-0"	2.5"	≥ 5'-1"
4'-0"	2.0"	3'-1"	4'-0"	2.0"	≥ 3'-1"
5'-0"	1.5"	1'-1"	5'-0"	1.5"	≥ 1'-1"
6'-0"	1.0"	1'-0"	6'-0"	1.0"	≥ 1'-0"
7'-0"*	1.0"	1'-0"	7'-0"	1.0"	≥ 1'-0"

*INSULATE UNDER PAVING, SIDEWALK AND DRIVEWAYS

DETAIL NO.: BSWSD: 26-18	BIG SKY WSD 363 STANDARD DRAWING	SCALE: NONE	BURIED WATER SERVICE LINE INSULATION	DATE: FEBRUARY 2010
				LAST REVISION: MAY 11, 2010
				CROSS REFERENCE WITH: N/A