



- NOTES:**
- A. 6' DIAMETER ECCENTRIC MANHOLE B ANDERSON PRECAST OF BOZEMAN OR BSWSD APPROVED EQUAL
 - B. MANUFACTURED TO ASTM C-478
 - C. RECESSED LIFTING POINTS IN ALL SECTIONS
 - D. MONOLITHIC TOP/BASE WITH WALLS
 - E. Z-LOK GASKETS TO FIT 1 1/2" OR 2" DIAMETER PIPE
 - F. M-A INDUSTRIES MANHOLE STEPS
 - G. GMI COMPOSITE MANHOLE COVER
 - H. CEMENT IS TYPE V
 - I. ALL CONCRETE IS 4500 PSI WITH 5% AIR ENTRAINMENT

DETAIL NO.: BSWSD: 26-29 B	BIG SKY WSD 363 STANDARD DRAWING	SCALE: NONE	IRRIGATION WATER VAULT - HORIZONTAL PLUMBING INSTALLATION	DATE: FEBRUARY 2010
				LAST REVISION: MAY 11, 2010
				CROSS REFERENCE WITH: N/A