



NOTE:
 ALL JOINTS BETWEEN MANHOLE SECTIONS, ADJUSTING RINGS, MANHOLE RING & TOP SECTION, AND AROUND WATER PIPE INLET AND OUTLET WITHIN MANHOLE SHALL BE WATERTIGHT. JOINTING MATERIAL SHALL BE "RAM-NEK" OR EQUAL FOR ALL JOINTS EXCEPT BETWEEN SEWER PIPE AND MANHOLE WALL WHERE LOK, WATERTIGHT BOOTS SHALL BE USED. GROUTING BETWEEN JOINTS WILL NOT BE ALLOWED.

DETAIL NO.:	BIG SKY WSD 363 STANDARD DRAWING	SCALE:	AIR RELEASE VALVE AND VAULT ," !%&" « K 5H9F.A5=BG	DATE:	FEBRUARY 2010
BSWSD:		NONE		LAST REVISION:	MAY 13, 2010
26-31				CROSS REFERENCE WITH:	N/A