



NOTE:
ALL JOINTS BETWEEN MANHOLE SECTIONS, ADJUSTING RINGS, MANHOLE RING & TOP SECTION, AND AROUND SEWER PIPE INTO MANHOLE SHALL BE WATERTIGHT. JOINTING MATERIAL SHALL BE "RAM-NEK" OR EQUAL FOR ALL JOINTS EXCEPT BETWEEN SEWER PIPE AND MANHOLE WALL WHERE GASKETED, FLEXIBLE, WATERTIGHT CONNECTIONS SHALL BE USED. GROUTING BETWEEN JOINTS WILL NOT BE ALLOWED.

DETAIL NO.:
BSWSD:
27-04

**BIG SKY WSD 363
STANDARD DRAWING**

SCALE:
NONE

**FLAT TOP SANITARY AND
STORM SEWER MANHOLE**

DATE: FEBRUARY 2010
LAST REVISION: MAY 4, 2010
CROSS REFERENCE WITH: N/A