



HORIZONTAL LAYER INSULATION			INVERTED U-INSULATION		
DEPTH OF BACKFILL OVER INSULATION	INSULATION THICKNESS	INSULATION WIDTH	DEPTH OF BACKFILL OVER INSULATION	INSULATION THICKNESS	$2B+A \geq$ WIDTH OF HORIZONTAL LAYER INSULATION
					$2B + A$
2'-0"	3.0"	6'-6"	2'-0"	3.0"	$\geq 6'-6"$
3'-0"	2.5"	6'-1"	3'-0"	2.5"	$\geq 6'-1"$
4'-0"	2.0"	4'-1"	4'-0"	2.0"	$\geq 4'-1"$
5'-0"	1.5"	2'-1"	5'-0"	1.5"	$\geq 2'-1"$

*INSULATE UNDER PAVING, SIDEWALK AND DRIVEWAYS

DETAIL NO.: BSWSD: 27-12	BIG SKY WSD 363 STANDARD DRAWING	SCALE: NONE	BURIED SEWER SERVICE LINE INSULATION	DATE: FEBRUARY 2010
				LAST REVISION: MAY 11, 2010
				CROSS REFERENCE WITH: N/A