



NOTE:
ALL JOINTS BETWEEN MANHOLE SECTIONS, ADJUSTING RINGS, MANHOLE RING & TOP SECTION, AND AROUND WATER PIPE INLET AND OUTLET WITHIN MANHOLE SHALL BE WATERTIGHT. JOINTING MATERIAL SHALL BE "RAM-NEK" OR EQUAL FOR ALL JOINTS EXCEPT BETWEEN SEWER PIPE AND MANHOLE WALL WHERE LOK, WATERTIGHT BOOTS SHALL BE USED. GROUTING BETWEEN JOINTS WILL NOT BE ALLOWED.

| | | | | |
|------------------------------------|---|--------------------|---|------------------------------|
| DETAIL NO.: BSWSD: 26-31 | BIG SKY WSD 363 STANDARD DRAWING | SCALE: NONE | AIR RELEASE VALVE AND VAULT 8"-12" Ø WATER MAINS | DATE: FEBRUARY 2010 |
| | | | | LAST REVISION: MARCH 2016 |
| | | | | CROSS REFERENCE WITH: N/A |
| | | | | |